

Exit & Emergency

Emergence Wet-Location Exit Series

- Wet-Location LED Polycarbonate Exit Sign
- Choice Of Red or Green Stencil Face
- Multiple Mounting Options
- Universal Single / Double Face
- Self-Test/Self-Diagnostics

Specifications

Description

Halco's Wet-Location Exit Sign Series offers a code compliant exit sign that was specifically designed for demanding environments. The EMG-WLEX utilizes a fully gasketed lens and housing to perform well in wet location installations.

Electrical

- 120 / 277 VAC, 60Hz input
- Self-testing/self-diagnostics with battery charging indicator
- Long-life maintenance free NiCad battery
- 24 hour recharge time
- -25°C - 50°C operating temperature

Certifications

- UL924 wet, cold location listed
- NFPA 101 and NFPA 70
- CEC T20 Compliant

EMERGENCE™
SERIES



Construction & Mounting

- Gasketed polycarbonate lens with 5VA thermoplastic housing
- Fully illuminated 6" characters with 3/4" stroke
- Field-selectable, snap in and out chevrons
- Suitable for wall, ceiling and end mount, canopy included
- Universal J-Box mounting pattern on back plate
- 5 year warranty

Exit & Emergency

Emergency Wet-Location Exit Series

Ordering Information

| Product SKU | Product Code | Product Description |
|-------------|---------------|--|
| 97108 | EMG-WLEX-WH-R | Emergency Wet-Location Exit with Red Lettering |
| 97109 | EMG-WLEX-WH-G | Emergency Wet-Location Exit with Green Lettering |

Specifications Table

| | EMG-WLEX-WH-R | EMG-WLEX-WH-G |
|-----------------------|--|---------------|
| Letter Color | Red | Green |
| Input | .25mA | |
| Wattage | 2.2W | |
| Battery | Ni-cad 3.6V400mAh | |
| Recharge Time | 24 Hours | |
| Input Voltage | 120 or 277 VAC | |
| Frequency | 60Hz | |
| Housing | Injection-Molded Thermoplastic Housing, Polycarbonate Lens | |
| Testing Function | Self-Testing/Self-Diagnostics | |
| Operating Temperature | -25°C to 50°C | |
| Listings & Compliance | UL 924, CEC Title 20, NFPA 70 & NFPA 101 | |
| Environment | Wet Location Listed | |
| Warranty* | 5 Year | |

*All life safety equipment, including emergency lighting for path of egress must be maintained, serviced, and tested in accordance with all National Fire Protection Association (NFPA) and local codes. Failure to perform the required maintenance, service, or testing could jeopardize the safety of occupants and will void all warranties.

Dimensions

