ProLED Select Flush Mount Mushroom Ring Installation Instructions



PLANNING THE INSTALLATION


Read all instructions before installation. Before starting installation of this fixture or removal of a previous fixture, disconnect the power by turning off the circuit breaker or by removing the fuse at the fuse box.

TOOLS REQUIRED





Wire Cutters



Wire Strippers


Electrical Tape

 \pm




ppers c

Phillips Screwdriver



Part	Description	Quantity
AA	Mounting Bracket	1
BB	Wire Nut	3
CC	30mm Machine Screw	2
DD	25mm Machine Screw	2
EE	Ground Screw	1

PACKAGE CONTENTS



Part	Description	Quantity
Α	Fixture Body	1
В	Cover	1

Installation




PREPARING THE FIXTURE




WARNING: Be sure the electricity to the wires you are working on is shut off. Either remove the fuse or turn the circuit off.

Remove the cover (B) from the fixture
(A) by turning it counterclockwise.




2 PREPARING THE MOUNTING BRACKET

- □ Align two of the threaded holes on the mounting bracket (AA) over one set of keyhole slots on the fixture (A).
- From the inside of the fixture (A), insert the 30mm screws (CC) and ground screw (EE) into the aligned holes, leaving approximately 1 in. of space between the screw heads and mounting bracket (AA).



3 INSTALLING THE MOUNTING BRACKET

 Attach the mounting bracket (AA) to the outlet box (not included) using the 25mm screws (DD).



raico Lignung technologies i 2940 Pacific Linve i Norcross, GA 3007 11 1011 Free add.or 7.3334 1 Priore 770.242.3012 1 Pax 300.300.00221 naicolignung.com i Auania i develanci i Houston i Los Angeles i Prioentix © 2022 Halco Lighting Technologies, LLC. All rights reserved. Halco and ProLED are registered trademarks of Halco Lighting Technologies. All sizes and specifications are subject to change. Print Edition 012022

ProLED Select Flush Mount Mushroom Ring Installation Instructions




Installation (cont.)

4 CONNECTING THE WIRES

- □ Connect the copper wire on the fixture (A) to the mounting bracket (AA) by securing it with the ground screw (EE).
- □ Use a wire connector (BB) to connect the ground wire from the fixture (A) to the ground wire from the outlet box.
- Use a wire connector (BB) to connect the white wire from the fixture (A) to the white wire (neutral wire) from the outlet box.
- □ Use a wire connector (BB) to connect the black wire from the fixture (A) to the black wire (live wire) from the outlet box.
- Wrap the three wire connections with electrical tape for a more secure connection.
- Position the wires inside the outlet box.

5 SECURING THE FIXTURE

Align the channels on the fixture with the screws (CC) protruding from the mounting bracket. Slide the fixture until it clicks into place over the screws (CC). Tighten the screws (CC) to secure the fixture (A) in place.



Safety Information




WARNING: RISK OF PERSONAL INJURY - PLEASE READ THESE INSTRUCTIONS CAREFULLY. FOLLOW ALL INSTALLATION INSTRUCTIONS AND OBSERVE ALL WARNINGS.

Retain these instructions. If you are an installer, please give these instructions to the property owner for future reference.

- Make sure the "supply" voltage corresponds to the "rated" product voltage 120V 60Hz.
- □ The product MUST be installed by a qualified electrician in accordance with The National Electrical Code and corresponding local codes.
- If the product is damaged, DO NOT ATTEMPT INSTALLATION AND DO NOT USE.


WARNING: Be sure the electricity to the wires you are working on is shut off. Either remove the fuse or turn the circuit off.



ATTACHING THE COVER

h

Switch to your desired CCT. Attach the cover (B) by turning it clockwise on the fixture (A).





WARNING: Risk of electrical shock: This product must be installed in accordance with the applicable installation code by a professional familiar with the construction and operation of the product. The professional should also be aware of, and understand the hazards involved with the installation of this product.



WARNING: Risk of fire: Always consult with a qualified electrician to ensure the correct branch circuit conductor is utilized. The minimum conductor rating requirement is 90°C (194°F) in order to be code compliant.



CAUTION: Risk of injury: Always wear the necessary safety equipment to prevent injuries when opening, handling, installing and maintaining this product.